



visair
CHILLED CABINETS



**Open Front
Food & Drinks Cabinet
700mm Refrigerant R-290**



**Copyright © September 2020 Future Products Group Limited.
All rights reserved.**

No part of this publication may be reproduced, stored in a retrieval system, or transmitted in any form or by any means, electronic, mechanical, photocopying, recording or otherwise, without the prior written permission of Future Products Group Ltd.

Warnings

Operational Safety	<p>This appliance is not intended for use by young children or infirm persons, unless they have been adequately supervised by a responsible person, to ensure that they can use the appliance safely.</p> <p>Young children should be supervised, to ensure that they do not play with the appliance.</p>
Water	<p>THIS UNIT IS NOT WATERPROOF. DO NOT USE A WATER JET SPRAY TO CLEAN THE INTERIOR OR EXTERIOR OF THIS CABINET.</p>
Caution	<p>Do not store explosive substances, such as aerosol cans with flammable propellant, in this appliance.</p>
Mains Supply Cord	<p>If the supply cord is damaged, it must be replaced by the manufacturer, its service agent or similarly qualified persons, in order to avoid a hazard.</p>
Specialist Disposal	<p>Specialist disposal procedures are required for the safe removal of refrigerant gasses and potentially flammable foam materials.</p> <p>Pentane, Dimethyl Ether, Isobutene, Butane and Propane may be present.</p>
Hazardous Substances	<p>The cabinet does not contain any of the following, in its construction:</p> <ul style="list-style-type: none">AsbestosPCBs (Oils containing polychlorinated biphenyl)Mercury
Obstructions	<p>Keep clear of obstructions, at ventilation openings in the appliance enclosure or in the structure for building-in.</p>
Defrosting	<p>Do not use mechanical devices or other means to accelerate the defrosting process, other than those recommended by the manufacturer.</p>
Damage	<p>Do not damage the refrigerating circuit.</p>



Table of Contents

WARNINGS	3
Operational Safety	3
Water	3
Caution	3
Mains Supply Cord	3
Specialist Disposal	3
Hazardous Substances	3
Obstructions	3
Defrosting	3
Damage	3
INTRODUCTION	8
Welcome	8
Future Products Group (FPG)	8
Guidance and Help	8
Warranty	8
Warranty Period	8
Liability Exceptions	9
Specific Exclusions	9
Assessment	9
Time Limit	9
Caution	9
OPERATION	10
Controls	10
Power, Lights and Refrigeration Controller	10
Preparation	10
Shelf Adjustment	10
Switch Power On	11
Load Cabinet	11
Loading Restrictions	11
Defrost Cycle	11
Routines	12
After Hours	12
Cleaning	12
De-frost Cycle	12
Temperature Checks	12
TROUBLE SHOOTING	13

CLEANING	14
Cautions	14
Power	14
Water	14
Exterior	14
Louvers	14
Painted and Metal Surfaces	14
Glass	14
Interior	15
Side Glass	15
Shelves	15
Base Tray	15
Back Plates	15
Cleaning the Base Cavity	16
Fan Deck and Drain Hole	16
Condensate Capacity Warning	16
Cooling Coil and Probes	16
Mandatory Cleaning Routines	17
Warning	17
Air Vents	17
Pre-filter	17
Condenser Radiator	17
Inspection and Rectification	17
INSTALLATION	18
Regulations	18
Compliance with Local Requirements	18
Setting Up	18
Unpacking	18
Cabinet Preparation	18
Positioning the Cabinet	18
Power Supply and Earthing	18
Isolation	18
Location	19
Ventilation	19
Draughts	19



SERVICING	20
Control Gear	20
Location	20
Access	20
Fuses	20
Lighting	21
Caution	21
LED Lighting Strips	21
Top Light Replacement	21
Shelf Light Replacement	21
LED Power Supplies	21
Refrigeration Equipment	22
Caution	22
Refrigeration Equipment	22
Compressor	22
Condensate Disposal	22
Access to Condenser Radiator and Control Gear	22
Control Gear	23
Evaporator Fan Replacement	23
Evaporator Coil	23
Air Ducts and Grills	24
Temperature Regulator XR70CX	24
Dixell Information	24
XR70CX Alarm Signals	26
XR70CX Connections	26
SPECIFICATIONS	27
Mechanical	27
Electrical	27
Cabinet Performance	28
Refrigerated Section Performance	28
Controller Settings	28
Dixell XR70CX Settings	28
Compliance	29
Standards	29
Improvements	29
Ongoing Development	29
ELECTRICAL CIRCUIT DIAGRAMS	30
Model: IN-VA07-B001-00	30
SPARE PARTS	31
Cabinet Serial Number	31
MECHANICAL DRAWINGS	32
Visair IN-VA07-B001-00	32

APPENDIX A R-290 REFRIGERANT	33
General Guidance	33
R-290	33
Servicing	33
Specialized Training	33
Environment	33
Gas Detector	33
Replacement Parts	33
Fault Diagnosis	33
Check List	33
Servicing	34
Gas Monitor	34
Ignition	34
Danger Sign	34
Display a Danger Propane placard to alert all that you are working on a R-290 system	34
No open flames or smoking is allowed	34
Fire Extinguisher	34
Access Fittings	34
Electrical Connectors	34
Replacement Components	34
Tools	35
Basic Tools	35
Required Tools	35
Leak Checking	36
Warning	36
Detection Methods	36
Accessing the Refrigeration System	36
Installing Piercing Valves	36
Procedure	36
Recovering Refrigerant	37
Recovery Machines	37
Procedure Without Machine	37
Venting R-290	38
Venting Procedures	38
System Evacuation	38
Preliminary Tasks	38
NOTE	38
Evacuation Procedure	39
Charging the System	39
WARNING	39
Precautions	39
Removal and Sealing of Access Ports	40
CAUTION	40
Procedure	40
Electrical Repairs	40
CAUTION	40
Guidelines	40
Check General Condition	41
R-290 SERVICING FLOW CHART	42



INTRODUCTION

Welcome

VISAIR CABINETS - INTRODUCTION

Future Products Group (FPG)

Welcome to the world of FPG! Our products are designed and engineered to give you the optimal performance that you deserve with innovative visual merchandising appeal.

We are confident that you will be delighted with your state of the art Inline Visair food service cabinet, and that it will become a valued appliance in your store.

Guidance and Help

Any new appliance can seem very complex and confusing at first glance. To ensure you receive the utmost benefit from your new Inline Visair cabinet, there are two things you can do.

- Before operating the cabinet, please read the instruction book carefully and follow its recommendations. The time taken will be well spent. These instructions both general and technical tell you how to operate and look after your Inline Visair food service cabinet so that you can receive the full benefits that this cabinet has to offer.
 - These instructions cannot, however, cover all eventualities. If you are unsure of any aspect of the installation, instructions or performance of your cabinet, contact your dealer promptly or contact us via email to support@fpgworld.com.
-

Warranty

VISAIR CABINETS - INTRODUCTION

Warranty Period

Future Products Group Limited warrants, to the original purchaser of an FPG manufactured food service cabinet that for ONE YEAR (12 months), from the date of installation, any defect in workmanship or material resulting in the product malfunctioning while under correct use will be rectified.

The warranty is extended to THREE YEARS (36 months), for refrigeration condenser units. Conditions apply, see Liability Exceptions.

Liability under this warranty is limited to replacing or repairing a part, without charge.

Continued on next page

Warranty cont.

VISAIR CABINETS - INTRODUCTION

Liability Exceptions

Liability under this warranty does not include:

- Any loss, or damage or expenses directly or indirectly arising from use or inability to use the product or from any other cause.
 - Any part of the cabinet which has been subject to misuse, neglect, alteration, incorrect installation, accident, or damage caused by transportation, use of abrasive or caustic chemicals, flooding, fire or acts of God.
 - Damage, resulting from failure to have the cabinet regularly serviced every three months by a refrigeration engineer. NB: You will be required to provide copies of service records in the event of compressor failure.
 - Any damage or malfunction resulting from the use of non-FPG supplied spare parts.
-

Specific Exclusions

The following are specifically excluded from warranty:

- Breakage of glass or plastic components or the replacement of LED lighting strips or gaskets.
 - Maladjustment of the electronic refrigeration controller, by an unqualified person.
 - Failure resulting from a lack of routine compressor / radiator cleaning.
 - Failure to re-assemble the cabinet correctly after cleaning.
 - Fair wear and tear.
-

Assessment

The liability under this warranty is dependent on an assessment by FPG, to determine the defect in workmanship or materials.

Time Limit

FPG does not guarantee that any service to be performed under this warranty will be carried out within any particular time limit.

Caution


No warranty claim will be accepted unless authorised by FPG prior to commencement of service.

OPERATION

Controls

VISAIR CABINETS - OPERATION

Power, Lights and Refrigeration Controller




Preparation

VISAIR CABINETS - OPERATION

Shelf Adjustment

- Push up
- Pull out
- Insert
- Push down



Preparation cont.

VISAIR CABINETS - OPERATION

Switch Power On



Press the power button.

The temperature controller is pre-set to maintain the cabinet temperature between 2°C and 4°C. It should not need adjustment.

Load Cabinet

After the cabinet has run for a 30 minute initial cool-down period, load it with pre-chilled products.

The cabinet is designed to maintain the temperature of pre-chilled products.

If warm product is introduced, there could be a delay before the temperature falls to the normal operating level.

Loading Restrictions

It is important to leave adequate free space for the refrigerated air to circulate within the cabinet.

Allow at least 40mm above canned drinks, or other cylindrical containers.

The air grills at the front of the cabinet must not be covered or restricted.

Defrost Cycle

Defrosting of the evaporator coil is fully automatic.

Defrosting stops automatically when all the ice has melted.

Routines

VISAIR CABINETS - OPERATION

After Hours



Ideally, cabinets should not be turned off after hours or at night.

Pull down the night blind, if fitted, and turn off the lights.

If the cabinet is turned off, transfer the products to a cool store. When the cabinet is turned on again, allow it to run for 30 minutes before returning the chilled products.

Cleaning

It is recommended to clean cabinets at the end of the working day, since they need to be shut down for this. See Cleaning section.

De-frost Cycle

Defrosting of the evaporator coil is fully automatic, taking place every two hours.

If you suspect that the defrost system is not working properly, have it checked by a qualified service person.

Operators must not attempt to adjust the refrigeration controller.

Temperature Checks

Cabinet temperatures should be routinely checked, to confirm satisfactory operation.

The refrigeration controller shows the temperature of the circulating air, as it enters the cooling coil. This will be slightly higher than the air temperature in the display area, so a temperature probe should be used to check product temperatures.

To avoid misleading temperature measurements, do not take a reading within 20 minutes of a defrost cycle.

TROUBLE SHOOTING

FAULT	POSSIBLE CAUSE	REMEDY
Cabinet does not operate/start	The mains isolating switch on the wall, circuit breaker or fuses are off at the power board	Turn isolating switch circuit breaker or fuses on
	The power switch on the controller is OFF	Press the power button
	The internal fuse has blown	<i>Have circuit checked and replace fuse</i>
	The controller is faulty	<i>Have the controller replaced</i>
HA2 Alarm Display on Controller	Compressor discharge pipe high temperature	Turn power off, clean condenser radiator & pre-filter. Turn power on. If no cooling, or alarm returns within 24 h, call for service.
Refrigerated Cabinet does not reach temperature	Ventilation grills are blocked	Vacuum or remove blockage
	Product blocking air grill	Place product on shelves
	Thermostat needs adjustment	<i>Adjust refrigeration controller</i>
	Ambient > 25°C & 60%RH	Adjust store air conditioning
	Evaporator coil iced up	<i>De-ice coil, check defrost parameters, replace controller if found faulty</i>
	Condenser radiator blocked	<i>Remove dust and debris</i>
	Refrigeration controller faulty	<i>Replace controller</i>
	Temperature probe damaged	<i>Replace temperature probe</i>
	Fans not operating	<i>Have fans checked/replaced</i>
Condensate Overflows	Defrost cycle unsuitable	<i>Have defrost cycle adjusted</i>
	Boil off element failed	<i>Replace element</i>
Cabinet lights not working	LED strip has failed	<i>Replace LED strip</i>
	LED power supply has failed	<i>Replace LED power supply</i>
	Internal fuse has blown	<i>Have circuit checked and replace fuse</i>
Aluminium parts corroded	Caustic detergent damage	Order replacement parts

Service Personnel Only

The table entries in ***italics*** indicate actions to be taken only by qualified Service Personnel.

CLEANING

Cautions

VISAIR CABINETS - CLEANING


Power **ALWAYS TURN THE POWER SUPPLY OFF BEFORE CLEANING.**

Water THIS UNIT IS NOT WATERPROOF. DO NOT USE A WATER JET SPRAY TO CLEAN THE INTERIOR OR EXTERIOR OF THIS CABINET.

Exterior

VISAIR CABINETS - CLEANING

Louvers



Painted and Metal Surfaces

Painted, galvanised steel or aluminium surfaces should be cleaned with hot soapy water then dried off with paper towel or dry cloth. DO NOT clean surfaces with abrasive pads or cleaners as paint, galvanised steel and aluminium surfaces will be damaged.

Glass

All glass should be cleaned using a good quality glass cleaner and a clean cloth.

DO NOT clean glass or mirrors with abrasive pads or cleaners as the surfaces will be damaged.


Interior

VISAIR CABINETS - CLEANING

Side Glass The inside surfaces of the side panels are most easily cleaned after the products and shelves have been removed.

Shelves The shelves can be cleaned in place, or lifted out.

Base Tray



Slide the base tray out to clean it.

Back Plates



The back plates can be cleaned in place.
If required, the plates can be removed by lifting them vertically.

Continued on next page

Interior cont.

VISAIR CABINETS - CLEANING


Cleaning the Base Cavity



With the base tray pulled out, sweep out, or use a vacuum cleaner, to remove any debris from the base cavity.

A Wet-and-Dry vacuum cleaner should be used, since there is likely to be some water in the bottom.

Fan Deck and Drain Hole



After removing the fixing screws, the fan deck can be lifted and unplugged from the cabinet for thorough cleaning.


Be careful not to trap the cables when it is replaced.

Check the drain hole is clear of debris.

Condensate Capacity Warning

When cleaning, **DO NOT** fill the well with liquid or attempt to hose it out, as the condensate tray will overflow and leak onto the floor.

Cooling Coil and Probes



With the back plates removed, the cooling coil is exposed. No cleaning is normally required, but if there is any debris visible, carefully remove it with a vacuum cleaner.

Be very careful not to bend or distort the fins of the cooling coil, as this would reduce the airflow.

Also be careful not to move or disturb the location of the two temperature probes. One is in free air, and the other is inserted between the fins of the coil.

Continued on next page

Mandatory Cleaning Routines

VISAIR CABINETS - CLEANING

Warning

It is mandatory to have the radiator fins cleaned periodically, by a refrigeration engineer. (see Servicing section).


Failure to carry out routine cleaning/servicing schedules will void the warranty on the refrigeration equipment.

To maintain optimum performance, cleaning must be regular and thorough. It is recommended that a schedule of cleaning operations should be drawn up.


Air Vents

Vacuum away any dust and fluff from all air vents.

The top air vents must be kept free of blockages at all times.



Pre-filter



Pull off the louver panel and pre-filter, shake dust from pre-filter and wash if needed.

Both the louver panel and the pre-filter are held in place by magnets.


When replacing the louver panel, locate the bottom edge first.

Condenser Radiator

Vacuum away any dust and fluff from the condenser radiator, to maintain good refrigeration efficiency.

Be careful not to bend or distort the radiator fins.

The radiator should be checked frequently and an appropriate cleaning schedule established to keep it clean.



Inspection and Rectification

As part of the cleaning routine, the controls, mechanical parts and electrical wiring should be inspected for damage, deterioration or need of adjustment.

Small faults should be attended to promptly, to avoid a complete breakdown.

INSTALLATION

Regulations

VISAIR CABINETS - INSTALLATION

Compliance with Local Requirements

It is very important that your food cabinet is installed correctly and is operating properly before use. Installation must comply with local electrical, health & safety and hygiene requirements.

Setting Up

VISAIR CABINETS - INSTALLATION

Unpacking

Unpack and check unit for damage and report any damage to the carrier and supplier. Report any deficiencies to your supplier.

Cabinet Preparation

Remove all tapes, ties and packers, used to prevent movement during transit. Pull the base drawer open to check for packing materials in the well.

Positioning the Cabinet

Position the cabinet in its allocated working position on the rollers.

If the floor is not level, place packing under the rollers to set the cabinet vertical.



Once in position, wind down the stabilizers, to prevent further movement.

Power Supply and Earthing

The cabinet is fitted with a four metre mains lead.

An EMI line filter is mounted adjacent to the mains inlet. If the cabinet is to be hard wired, this must only be done by a suitably qualified person.

Before connecting to the power supply, check that the local supply is correct to that shown on the cabinet label.

WARNING - THE CABINET MUST BE EARTHED/GROUNDED

Isolation

If the cabinet is not connected to an outlet socket, but is hard wired to the mains supply, a means of isolation must be provided.

If a plug and socket are used, they should still be accessible after the cabinet is installed.

Location

VISAIR CABINETS - INSTALLATION

Ventilation

The front louvers and vents located on the top of the cabinet must never be obstructed. If obstructed the cabinet may overheat and cause an electrical malfunction.

If the cabinet is installed in an alcove, or under any structure, a minimum clearance space of 200mm must exist above the cabinet top.

Before use, operate the cabinet for 1-2 hours to remove any fumes or odours, which may be present.

Draughts

The door-less cabinet features an “air curtain” to retain the cold air within the cabinet. A “curtain” of cold air falls from a linear vent, across the top of the open cabinet front, to be re-circulated through the evaporator cooling coils.

The cabinet should not be sited where strong draughts will deflect the “air curtain”. If this happens, excess condensation will form on the products, and cooling will be less effective.

SERVICING

Control Gear


VISAIR CABINETS - SERVICING

Location




The control gear is located on a chassis behind the control panel.


Access



Remove screw to release the chassis.



Remove three screws to take off cover plate.



Fuses



Unlatch the fuse carrier and open it to replace the fuse link.

Lighting

VISAIR CABINETS - SERVICING

Caution DO NOT service the lights, without isolating the cabinet at the main switch or unplugging it from the electricity supply.

LED Lighting Strips Light is provided by LED strips, under the top of the cabinet and each shelf. The LED modules have a very long life, but if they fail, the complete strip should be replaced.

Top Light Replacement



The LED strip is self-adhesive, with soldered connections.

Unsolder the joints to replace the strip.


Ensure correct polarity when reconnecting.

Shelf Light Replacement

The shelf lights are connected by plug and socket. A complete replacement assembly should be fitted if a strip fails.

LED Power Supplies

The lights are fed with a 24Vdc constant voltage from a power supply located behind the back panel.



Refrigeration Equipment


VISAIR CABINETS - SERVICING

Caution

DO NOT attempt to service the refrigeration equipment without isolating the cabinet from the mains supply.

The condenser uses R-290 refrigerant, so read Appendix A before proceeding.

Refrigeration Equipment



The compressor, condenser fan and condensate disposal system are mounted in the base of the cabinet, behind the condenser radiator.

Unscrew the lower back panel to gain access.

Compressor

The compressor is hermetically sealed.


It is fitted with a dryer, an overtemperature probe.

No access ports are provided for pressure monitoring or charging with refrigerant. Read Appendix A for servicing instructions.

Condensate Disposal

The condensate disposal system consists of a water tray with two heating elements. The elements have a positive temperature coefficient, reducing power when there is no water present.

Access to Condenser Radiator and Control Gear



To access the condenser radiator and control gear, simply pull the louver panel forward, to disengage the magnetic catches.

It is vital that the pre-filter and radiator are kept clean. If air flow is restricted, refrigeration efficiency will be poor.


The radiator fins must be regularly cleaned, using compressed air. Do this at least every six months, or more often if needed.

Continued on next page

Refrigeration Equipment cont.

VISAIR CABINETS - SERVICING


Control Gear



The refrigeration controller, fuses and associated compressor relay are all mounted on this chassis.

The high temperature sensing probe is on the compressor assembly.

Evaporator Fan Replacement



The fan deck is connected to the cabinet with a plug and socket, and can be withdrawn to replace a faulty fan, after removing the fixing screws.

The fan speed is electronically programmed, so the correct spare must be used.


Evaporator Coil



The evaporator coil and temperature probes are accessed by removing the inside back panel of the cabinet.

Take care not to disturb the location of the two probes.

One probe is in the air flow, the other in the coil fins.



Refrigeration Equipment cont.

VISAIR CABINETS - SERVICING

Air Ducts and Grills

All air ducts, grills and louvers must be regularly vacuumed, to keep them free of dust and fluff.

This is best done after cleaning the condenser radiator with compressed air.

Grills are located on the top of the cabinet and louvers on the front bottom panel.



Temperature Regulator XR70CX




Model XR70CX is a microprocessor-based controller. It is provided with four NTC probes. The first one for temperature control (air off), the second

one, located on the evaporator coil, to control the defrost termination, the third one senses the temperature of the compressor discharge pipe.

Another probe is connected to the Pb4 input. It is located at the input side of the evaporator coil, and is used to display the temperature of air returning from the cabinet interior.

The indicated set-point temperature will be lower than the air temperature inside the cabinet, because the refrigeration compressor is controlled in response to the exit air (air off) temperature from the evaporator cooling coils.

The instrument is fully configurable through special parameters that can be easily programmed through the keyboard.



Dixell Information

Additional information about the Dixell XR70 can be found at:

<http://www.dixell.de/en/Dixell/artikel/11178>








webapps.emerson.com › Manuals › PRIME › XR70CX › XR70CX-GB

Continued on next page








Refrigeration cont.

VISAIR CABINETS - SERVICING

XR70CX Key Functions

KEY	FUNCTION
SET	To display target set point; in programming mode it selects a parameter or confirm an operation
	(DEF) To start a manual defrost
	(UP): To see the max. stored temperature; in programming mode it browses the parameter codes or increases the displayed value
	(DOWN): To see the min stored temperature; in programming mode it browses the parameter codes or decreases the displayed value
	To switch the instrument off, if onF = oFF. Not enabled
	To lock & unlock the keyboard
SET + 	To enter into programming mode
SET + 	To return to the temperature display mode

XR70CX LED Functions

LED	MODE	FUNCTION
	ON	Compressor enabled
	Flashing	Anti-short cycle delay enabled
	ON	Defrost enabled
	Flashing	Drip time in progress
	ON	An alarm is occurring
	ON	Continuous cycle is running
	ON	Energy saving enabled
°C/°F	ON	Measurement unit
°C/°F	Flashing	Programming phase

Continued on next page

Refrigeration cont.

VISAIR CABINETS - SERVICING

XR70CX Alarm Signals

Message	Cause	Outputs
P1	Room probe failure	Compressor output acc. to par. Con and COF
P2	Evaporator probe failure	Defrost end is timed
P3	Third probe failure	Outputs unchanged
P4	Fourth probe failure	Outputs unchanged
HA	Maximum temperature alarm	Outputs unchanged.
LA	Minimum temperature alarm	Outputs unchanged.
HA2	Condenser high temperature	It depends on the Ac2 parameter
LA2	Condenser low temperature	It depends on the bLL parameter
dA	Door open	Compressor according to rrd
EA	External alarm	Output unchanged.
CA	Serious external alarm (i1 F=bAL)	All outputs OFF.
CA	Pressure switch alarm (i1 F=PAL)	All outputs OFF

XR70CX Alarm Recovery

Probe alarms P1, P2, P3 and P4 start some seconds after the fault in the related probe; they automatically stop some seconds after the probe restarts normal operation. Check connections before replacing the probe.


Temperature alarms HA, LA, HA2 and LA2 automatically stop as soon as the temperature returns to normal values.

Alarms EA and CA (with i1 F=bAL) recover as soon as the digital input is disabled. Alarm CA (with i1 F=PAL) recovers only by switching off and on the instrument.

XR70CX Other Messages

Message	Cause
Pon	Keyboard unlocked.
PoF	Keyboard locked
noP	In programming mode: none parameter is present in Pr1 On the display or in dP2, dP3, dP4: the selected probe is not enabled
noA	No alarm is recorded.

XR70CX Connections



SPECIFICATIONS

Mechanical

VISAIR CABINETS - SPECIFICATIONS

	CABINET MODEL				
	IN-VA07-B001-00				
Height mm	1499				
Width mm	707				
Depth mm	813				
Dry Weight kg					
Cabinet Well Material	Stainless steel				
Number of Shelves	3				
Display Area m ²	0.63 (shelves) + 0.22 (base)				
Refrigerant	R-290				
Refrigerant Charge	Refer to cabinet Serial No./Rating label				
Condensate capacity	5 litres				
Climatic Class & IP Rating	All cabinets are suitable for class N climates and have an IP X0 rating				

Electrical

VISAIR CABINETS - SPECIFICATIONS

	CABINET MODEL				
	IN-VA07-B001-00				
Voltage	220-240 V 50 Hz 1 ϕ				
Power	1.4 kW				
Energy Consumption	0.65 kWh/h				
Current	6.2 A				
Connection	3 core cable with 10A plug				
Temperature Range, °C	2 - 4°				
Lights	4 x LED strip				



Cabinet Performance

VISAIR CABINETS - SPECIFICATIONS

Refrigerated Section Performance

Operating Temperature	Average Internal Humidity	Climatic Class 3 Test Conditions
+2° to +4°C	N/A	25°C Ambient with 60% RH

Controller Settings

VISAIR CABINETS - SPECIFICATIONS

Dixell XR70CX Settings

	Parameter	IN-VA07-B001				Units / Range
		Integral				
Set Point	Set	-6				degC
Differential	Hy	6				degC
Third Probe Presence	P3P	Y				N,Y
Fourth Probe Presence	P4P	Y				N,Y
Anti Short Cycle Delay	AC	0				Min
Comp On Time - Faulty Probe	Con	4				Min
Comp Off Time - Faulty Probe	CoF	6				Min
Probe Displayed	Lod	P4				P1, P2, P3, P4
Defrost Terminate Temp	dtE	6				degC
Interval Between Defrosts	ldF	2				Hrs
Display During Defrost	dFd	DEF				rt, it, Set, DEF
Fan Operating Mode	Fnc	o-Y				C-n, o-n, C-Y, o-Y
Fan Delay After Defrost	Fnd	0				Min
Probe For Fan Management	FAP	nP				nP, P1, P2, P3, P4
Probe For High Discharge Temp Alarm	AP2	P3				nP, P1, P2, P3, P4
High Discharge Temp Alarm Set Point	AU2	90				degC
High Discharge Temp Alarm Diff	AH2	25				degC
High Discharge Temp Alarm Delay	Ad2	0				Min
High Discharge Temp Alarm Delay At Start	dA2	0				Min
Comp Off For High Discharge Temp Alarm	AC2	Y				n, Y
Fourth Relay Configuration	oA3	LiG				Alr, dEF, LiG, AUS, AUX, onF, Fan, db, CP2, dF2.
On/Off Key Enabling	onF	oFF				nu, oFF, ES

Compliance

VISAIR CABINETS - SPECIFICATIONS

Standards	<p>FPG refrigerated, controlled ambient and ambient food display cabinets are designed to meet and exceed:</p> <ul style="list-style-type: none">• International safety standards for electrical appliances: IEC 60335-1, IEC 60335-2-89, and the equivalent country-specific standards including AS/NZS, BS EN and UL 471.• International standards for electromagnetic compatibility/emissions: CISPR 14-1, and the equivalent county-specific standards including AS/NZS CISPR and BS EN 55014-1.• Essential safety requirements: AS/NZS 3820 and AS/NZS 4417• Energy efficiency for refrigerated appliances: MEPS (Australia/New Zealand) <p>Please contact FPG to discuss your requirements for meeting country-specific standards.</p>
------------------	---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

Improvements


VISAIR CABINETS - SPECIFICATIONS

Ongoing Development	<p>FPG reserves the right to change specifications and construction, as part of ongoing product improvement.</p>
----------------------------	------------------------------------------------------------------------------------------------------------------

ELECTRICAL CIRCUIT DIAGRAMS

Model: IN-VA07-B001-00

Visair Refrigerated Cabinets



SPARE PARTS

Cabinet Serial Number

When ordering spare parts, it is important to quote the Serial Number printed on the label fixed to the control panel.


This serial number will enable FPG to trace details of the build specification of your particular cabinet, and hence ensure that spare parts are fully compatible.

To satisfy warranty conditions, and ensure optimum performance, use only FPG supplied spare parts.

Part Description	FPG Part No.
LED power supply 24V 60W	28726
Mains EMI Line Filter	30828
Anti-surge thermistor 10 Ohm 3A	22354
Top light replacement LED lighting strip	30548
Shelf replacement LED lighting assembly	76125
Dixell XR70cx Refrigeration Controller	30647
NTC temperature probe (with plug)	20943
NTC temperature probe (without plug)	22553
Evaporator fan, EBM 1300rpm	75741
Permalon pre-filter element	30632
Fuse link 5A	13330
330 watt 230V PTC ACR element	27751
Compressor control relay	30483
Deck tray runner	16717
Visair cabinet toughened side glass kit, left hand	76132
Visair cabinet toughened side glass kit, right hand	76133
Acrylic Air Dam	30628
Night Blind	30598
Condenser Embraco UNT 6217 U R290	30601
Product Manual for VA07 Open Front Food & Drinks Cabinet	30911

MECHANICAL DRAWINGS

Visair IN-VA07-B001-00



APPENDIX A R-290 Refrigerant

General Guidance

*VISAIR CABINETS - APPENDIX A
R-290 Refrigerant*



R-290	<p>R-290 is the name for refrigerant grade high purity odorless propane. It is NOT barbeque grill propane. PROPANE IS HIGHLY FLAMMABLE. You MUST observe caution and proper safety practices when servicing equipment with R-290.</p>
Servicing	<p>Servicing refers to making repairs to the hermetically-sealed system and any parts of the electrical system.</p>
Specialized Training	<p>Although not mandatory, specialized training of service personnel is desirable.</p>
Environment	<p>Repair on R-290 equipment should always be done in a well ventilated area.</p>
Gas Detector	<p>Because R-290 is highly flammable, an electronic combustible gas leak detector is required when servicing R-290 systems.</p>
Replacement Parts	<p>When opening any refrigeration system, the filter/dryer must be replaced with the manufacturers specified spare part.</p>
Fault Diagnosis	<p>Since there are no access fittings on R-290 systems, temperatures and current draw must be used to evaluate system performance.</p>
Check List	<p>Before proceeding with servicing, check the following:</p> <p>MONITOR: make sure the combustible-gas meter is on and in proper position. VENTILATE: make sure there is adequate ventilation in the work area. ELIMINATE: make sure to eliminate any potential ignition sources.</p>

Servicing

VISAIR CABINETS - APPENDIX A
R-290 Refrigerant

Gas Monitor Before entering any service area that may have hydrocarbons, always turn on a combustible gas monitor to alert you to the presence of flammable refrigerants while you are working.

Do not turn the combustible gas monitor off until you leave the service area.

Ignition Do not unplug, disconnect power to, or begin servicing a system before checking for flammable refrigerants with the combustible gas monitor.

Sparks from unplugging or power disconnects could ignite flammable refrigerants.

Danger Sign Display a Danger Propane placard to alert all that you are working on a R-290 system.

No open flames or smoking is allowed.

Instruct anyone in the immediate area the nature of the work taking place.

Be aware that E-cigarettes or similar electronic devices could be a source of ignition.



Fire Extinguisher An approved fire extinguisher is required when servicing a system that contains a flammable refrigerant.

Access Fittings Since access fittings are not supplied on any R-290 systems. Before adding access-fittings you should check temperatures and amps and contact FPG for guidance on fault finding.

Electrical Connectors



Wire nuts are not approved for R-290. All connectors must be UL approved for use with Hydrocarbons.

Wire connectors must have sufficient strength to hold the conductor/wire in place.

Replacement Components When replacing components, ignition-proof sealed electrical components are required.












To avoid using unapproved parts, only FPG replacement parts are to be used on a R-290 system.

Tools

VISAIR CABINETS - APPENDIX A
R-290 Refrigerant

Basic Tools Use the same basic refrigeration tools as for R404-A & R-134a refrigerant.

Required Tools

	<p>Combustible gas leak detector (Inficon Gas Mate) or equal</p>		<p>Propane warning notice</p>
	<p>Tubing cutter</p>		<p>Approved fire extinguisher (Class B dry powder type)</p>
	<p>Vacuum gauge</p>		<p>30cm charging hose (low Loss design)</p>
	<p>Ball charging valves (3)</p>		<p>Gram scale</p>
	<p>Tap valves 1/4" (2)</p>		<p>Digital thermometer</p>
	<p>Pinch off tool (2)</p>		<p>Venting hose</p>



Leak Checking

VISAIR CABINETS - APPENDIX A
R-290 Refrigerant

Warning Do NOT use any leak test dyes when working on an R-290 refrigeration system.

Detection Methods

- Bubble test.
- Electronic combustible gas detection.
- Nitrogen holding pressure test (only possible on accessed systems).

For the most part, you would leak check a R-290 system the same way you would a R-134a or R-404A system with a couple of exceptions.

You cannot use a halide leak detector on an R-290 system, the electronic leak detector must be designed specifically for combustible gas.

Using oxygen-free dry nitrogen with a trace gas not exceeding 150PSIG is also recommended.

Accessing the Refrigeration System





VISAIR CABINETS - APPENDIX A
R-290 Refrigerant

Installing Piercing Valves

Line tap valves can be used to access the refrigeration system. Line tap valves should be temporarily placed on the suction and liquid process tubes.

IMPORTANT: Never leave piercing valves of any type on the R-290 refrigeration system. This would void the warranty.

Procedure

Make sure the cabinet is disconnected from the power source. Wear safety glasses and gloves (rubber coated are best).	
Turn the combustible-gas leak detector "ON". Refer to the manufacturer's instructions for the detector you are using.	
Post the warning notice in plain view for all to see on the front and rear of the refrigeration appliance.	
Remove the red sleeves on the suction and liquid line process tubes. Install the piercing valves following manufacturer's instructions. Red sleeves must be replaced when done servicing.	

Recovering Refrigerant

VISAIR CABINETS - APPENDIX A
R-290 Refrigerant

Recovery Machines

Recovery machines for use with hydrocarbon refrigerants are in limited production.

Only an explosion proof recovery machine can be used to recover.

Procedure Without Machine

1. Evacuate an empty recovery cylinder into a vacuum.
2. Using an accurate refrigerant scale, zero out the refrigerant scale and weigh the empty recovery cylinder prior to adding refrigerant gauges or hoses. Note this weight.
3. Securely connect the evacuated cylinder to the refrigeration system using refrigerant gauges and hoses.
4. Open both refrigerant gauges to allow refrigerant to flow through the gauges to the recovery cylinder. You must evacuate from both sides.
5. Once the pressures have equalized, valve off the refrigerant gauges and the recovery cylinder securely.
6. Carefully remove the refrigerant hose from the recovery cylinder.
7. Zero out the refrigerant scale and weigh the recovery cylinder. Note this weight.
8. Subtract the empty tank weight recorded from the cylinder now containing the refrigerant. This will be the amount recovered.
NOTE: You can check Serial Label to verify any leak.
9. A recovery cylinder containing R-290 can be vented outdoors. See "Venting R-290" for instructions on venting R-290.
10. After venting the refrigerant, purge the recovery cylinder with nitrogen at a flow rate of 5PSIG through the liquid port of the recovery cylinder for 2 minutes outdoors, 3 metres away perimeter from any structures or ignition sources.
11. Repeat steps 1-9 until the recovery cylinder and the system equalize into a vacuum.

NOTE: Trace amounts of R-290 will remain trapped in the POE oil of the compressor.



Venting R-290

VISAIR CABINETS - APPENDIX A
R-290 Refrigerant

Venting Procedures

1. Do NOT vent hydrocarbon refrigerants inside a building under any circumstance (SAFETY RISK).
 2. Venting hydrocarbon refrigerants to a public area or where people are unaware of the procedure is not permitted.
 3. When venting R-290 YOU MUST make everyone in the immediate area aware that you are venting a flammable gas to the atmosphere.
 4. Ensure there are no ignition sources within a 10 ft. perimeter of the area you are venting R-290. Be aware that E-cigarettes or similar electronic devices could be a source an ignition.
 5. Ensure that all local legislation/regulations addressing safety of hazardous or flammable substances are satisfied.
 6. Ensure you are not venting R-290 into a low-lying area. R-290 is heavier than air and can accumulate in floor drains, grease traps, piping troughs, etc.
 7. After venting, purge with Nitrogen through the system for a minimum of 10 seconds.
-

System Evacuation

VISAIR CABINETS - APPENDIX A
R-290 Refrigerant

Preliminary Tasks

Prior to sealing up the system make sure you have a sufficient amount of service access tubing remaining for service in the future.

1. Remove the crimped tubing and piercing/saddle valve from the process tube.
2. Extend the process tube a minimum of 30cm.
3. Crimp and braze the process tube extension.
4. Install piercing/saddle valve just before last crimp.

After the system has been sealed and leak checked, it is necessary to evacuate it in order to remove air, moisture, and unwanted residual refrigerant.

NOTE

Technician must use tube cutter instead of torch when removing refrigeration system components.

System Evacuation cont.

VISAIR CABINETS - APPENDIX A
R-290 Refrigerant

- | | |
|-----------------------------|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| Evacuation Procedure | <ol style="list-style-type: none">1. It is necessary to purge the system with nitrogen. This is necessary to prevent flammable mixtures from occurring.2. When connecting the hoses between the system, gauge manifolds, and vacuum pump, ensure that the connections are secure and there are no potential ignition sources nearby.3. Ensure that the pump discharge is in an area free of potential ignition sources.4. Ensure that a micron gauge is used since conventional manifold gauges may not provide a proper reading.5. The system should be evacuated to the desired pressure (typically 250 microns or less) and then left to stand for 15 minutes to ensure that the entire refrigerant charge has been removed from the oil and any residual moisture has been evaporated from the system.6. Ensure that the vacuum pump is of good quality and of appropriate capacity for the system, and the oil level is correct. |
|-----------------------------|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
-

Charging the System

VISAIR CABINETS - APPENDIX A
R-290 Refrigerant

WARNING	Dial-a-charge cylinders, with a sight glass, should not be used to charge systems with flammable refrigerant.
----------------	----------------------------------------------------------------------------------------------------------------------

- | | |
|--------------------|-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| Precautions | <p>Although charging procedures are similar to those used with any other type of refrigerant, the following considerations are important for R-290:</p> <ul style="list-style-type: none">• Prior to charging, ensure the system has been leak checked.• Hoses or lines must be as short as possible to minimize the amount of refrigerant contained in them.• Evacuate the hoses and manifold prior to charging to avoid contamination of the refrigerant.• Upon completion of charging, a further leak check must be carried out prior to leaving the site.• After charging, carefully disconnect the hoses, attempting to minimize the release of refrigerant.• After charging, all access ports/points must be removed following the correct procedures. |
|--------------------|-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|

**DO NOT OVERCHARGE A SYSTEM USING R-290.
Weigh in the exact charge.**

Removal and Sealing of Access Ports

VISAIR CABINETS - APPENDIX A
R-290 Refrigerant

CAUTION Do not leave piercing valves on the system.

Procedure

1. Pinch line off just before the temporary access port two times using a crimping tool. Keep crimping tool in place as shown in photo.
2. Verify that there are no leaks.
3. Remove the piercing valve/temporary access port.
4. Snap off at "crimp 1" and check for leaks.
5. Braze open end shut while crimping tool is in place.
6. Leak check the system, with crimping tool removed.



Electrical Repairs

VISAIR CABINETS - APPENDIX A
R-290 Refrigerant

CAUTION The electrical power to the equipment must be disconnected. A combustible-gas leak detector must be on at all times.

Protect yourself from hazards of working on the electrical components by following some basic guidelines before you begin the repair. Prior to starting your repair work on an electrical component, use your combustible gas detector to see if flammable gas is present.

Only when the area is clear of any flammable gas should you start the repair.

Guidelines

- Do not use components that produce sparks, discharge, etc.
- Components that could produce a potential ignition source need to be positioned in an area, distant and unreachable, from any potential refrigerant leak.
- FPG components are designed for use with flammable refrigerants.
- Do not replace faulty components that are intended not to spark with components that do. ONLY use FPG recommended spares.
- Do not modify components that are intended not to spark in such a way that they will spark.

Electrical Repairs cont.

VISAIR CABINETS - APPENDIX A
R-290 Refrigerant

Check General Condition

You may not be the first person that has worked on this system.

- Check all components for unauthorized/non-OEM replacement parts.
 - Look beyond your repair for any wear, stresses, that could become an ignition source. Are terminal connections tight and in a UL approved connectors?
 - Check all protective conductors' connections each time you access a system or repair is made.
 - Finally, check the plug, cabling and wiring for any damage.
-



R-290 SERVICING FLOW CHART

Before starting work on the R-290 system, turn on the gas-leak detector and place it on the floor, next to the cabinet.

	Refrigeration Circuit Access	Comments
1	Disconnect electrical supply to appliance.	If possible, ground the appliance to avoid static electric sparks.
2	Access condenser/compressor and install two piercing valves.	Vent both the high and low side of the system in case there is a blocked cap tube and/or drier.
3	Connect your refrigeration gauge equipped with 30cm hoses to the two piercing valves.	
4	Connect the yellow hose of your gauge set to a recovery bag or a venting tube, if a safe venting location is available.	
5	Once the charge is removed, connect the Nitrogen tank.	
6	Purge Nitrogen through the system for a min. of 10 seconds.	If using a recovery bag, be sure to take it to a safe location and vent.
7	Always cut the compressor or other components out with a tubing cutter.	
8	Purge Nitrogen through the system at 70 to 140 hPa, before any parts must be un-brazed.	
9	Purge Nitrogen through system at 70 to 140 hPa, while brazing in new components.	

	Installing New Components	Comments
1	Remove old compressor, drier and any other defective component.	If the compressor is removed, seal the suction and discharged tubes to prevent a spill.
2	Install new FPG approved spare parts.	A new dryer must be fitted if the compressor is replaced.
3	If the two access line tubes are not at least 30cm long, add more tube with brazed pinched-off ends. Reinstall tap valves.	Access tubing lines may need to be braced to prevent bending over.
4	Purge with Nitrogen again at 70 to 140 hPa while brazing. Wrap drier with wet rag when brazing.	
5	Fill the system with Nitrogen to 1000 kPa and check for leaks.	
6	Release Nitrogen and pull a vacuum on the system to 250 microns or less. Turn off the vacuum and confirm that it holds the vacuum.	
7	If vacuum holds, the system can now be charged.	Propane labelled 'R-290 Refrigerant' must be used. DO NOT USE BBQ PROPANE.
8	Purge the charging hoses and ready your gauge set and hoses so they will not move during the charging process.	
9	Check the cabinet Serial Number label for the required charge.	
10	Use the ball valves installed on your hose to meter in the charge.	Because the charge is small, take care and be precise.
11	Charge the circuit. (preferred method of charging is to charge liquid into liquid line).	
12	If new starting components have been fitted, check electrical connections and install all terminal covers.	FPG compressor start components are designed for use with HC refrigerants. Do not use non-FPG approved spare parts.
13	Start the system and check operation. Do a final check for leaks	

VISAIR CABINETS

In line with our policy to continually develop, improve and support our products, Future Products Group Ltd reserves the right to change specifications and design without notice.

Have a question? Please email us at support@fpgworld.com or visit WWW.FPGWORLD.COM for full contact details for your region.

